

Luminaire Photograph



Light Output Ratio:	19.1%	
Luminaire Power:	14.34 W	
SHR Nominal:	0.00	Calculated using the TM5
SHR Maximum:	0.10	fine grid method.

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature: 25.3 °C
Operators: zoe
Test Date: 2023-6-19

Range: 0 - 180DEG
Interval: 1.0DEG
Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.461
Humidity: 65.0%
Test Distance: 3.160m [K=1.0000]
Remarks: LAMP: BXRE-30H1000-A-83 Ra: 97
LENS: 20R
DRIVER: RMS-15-350AS 350mA
30minutes warm-up

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM




Fig. C0/C180

Fig. C90/C270


C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature: 25.3 °C
Operators: zoe
Test Date: 2023-6-19

Range: 0 - 180DEG
Interval: 1.0DEG
Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.461
Humidity: 65.0%
Test Distance: 3.160m [K=1.0000]
Remarks: LAMP: BXRE-30H1000-A-83 Ra: 97
LENS: 20R
DRIVER: RMS-15-350AS 350mA
30minutes warm-up

LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:220.08V I:0.0681A P:14.339W PF:0.9540 Freq:49.99Hz Lamp Flux:1339.9x1 lm		
NAME: 2319.201F-AD3-350	TYPE:	WEIGHT:
SPEC.: 3000K	DIM.:	SERIAL No.: 2306190791
MFR.: RISE	SUR.: 0.00101736m2	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 17.88 lm/W			
MODEL	Brideglux	Imax(cd)	2062	S/MH(C0/180)	0.29
NOMINAL POWER(W)	14	LOR(%)	19.1	S/MH(C90/270)	0.29
RATED VOLTAGE(V)	220	TOTAL FLUX(lm)	256.38	UP,DN(C0-180)	0.0,10.3
NOMINAL FLUX(lm)	1339.9	CIE CLASS	DIRECT	UP,DN(C180-360)	0.0,8.8
LAMPS INSIDE	1	up(%)	0.0	CIBSE SHR NOM	0.00
TEST VOLTAGE(V)	220	down(%)	19.1	CIBSE SHR MAX	0.10



C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:zoe
Test Date:2023-6-19

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.461
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks: LAMP:BXRE-30H1000-A-83 Ra:97
LENS: 20R
DRIVER:RMS-15-350AS 350mA
30minutes warm-up

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

	C0	C45	C90	C135	C180	C225	C270	C315		zone	total	%lum,lamp
10	1818	1797	1791	1758	1740	1751	1771	1806	0- 10	181.0	181.0	70.6,13.5
20	4.849	4.518	4.437	4.386	2.351	2.474	2.799	2.893	10- 20	64.23	245.3	95.7,18.3
30	13.82	11.63	7.407	5.004	4.332	7.100	12.95	15.97	20- 30	3.164	248.4	96.9,18.5
40	6.506	6.277	5.891	3.951	3.350	5.071	6.040	8.092	30- 40	5.302	253.7	99,18.9
50	1.016	0.8207	1.063	0.7769	0.7900	0.8291	0.7004	1.025	40- 50	2.292	256.0	99.9,19.1
60	0.1299	0.1319	0.1382	0.1421	0.1164	0.1132	0.1196	0.1165	50- 60	0.3136	256.3	100,19.1
70	0.0025	0.0014	0.0037	0.0071	0.0050	0.0020	0.0031	0.0002	60- 70	0.0391	256.4	100,19.1
80	0.0003	0	0.0003	0.0000	0	0	0.0012	0	70- 80	0.0016	256.4	100,19.1
90	0	0	0	0	0	0	0	0	80- 90	0.0006	256.4	100,19.1
100	0	0	0	0	0	0	0	0	90-100	0	256.4	100,19.1
110	0	0	0	0	0	0	0	0	100-110	0	256.4	100,19.1
120	0	0	0	0	0	0	0	0	110-120	0	256.4	100,19.1
130	0	0	0	0	0	0	0	0	120-130	0	256.4	100,19.1
140	0	0	0	0	0	0	0	0	130-140	0	256.4	100,19.1
150	0	0	0	0	0	0	0	0	140-150	0	256.4	100,19.1
160	0	0	0	0	0	0	0	0	150-160	0	256.4	100,19.1
170	0	0	0	0	0	0	0	0	160-170	0	256.4	100,19.1
180	0	0	0	0	0	0	0	0	170-180	0	256.4	100,19.1
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:zoe
Test Date:2023-6-19

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.461
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks: LAMP:BXRE-30H1000-A-83 Ra:97
LENS: 20R
DRIVER:RMS-15-350AS 350mA
30minutes warm-up

LUMINANCE LIMITATION CURVES

Test:U:220.08V I:0.0681A P:14.339W PF:0.9540 Freq:49.99Hz
Lamp Flux:1339.9x1 lm

NAME: 2319.201F-AD3-350

TYPE:

WEIGHT:

SPEC.: 3000K


DIM.:

SERIAL No.: 2306190791

MFR.: RISE

SUR.: 0.00101736m2

Shielding Angle:



LUMINANCE cd/(m2)		
G(180)	C0/180	C90/270
85	0	0
80	2	2
75	2	18
70	7	11
65	67	81
60	255	272
55	544	549
50	1550	1628
45	4636	4472


C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:zoe
Test Date:2023-6-19

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.461
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks: LAMP:BXRE-30H1000-A-83 Ra:97
LENS: 20R
DRIVER:RMS-15-350AS 350mA
30minutes warm-up

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:220.08V I:0.0681A P:14.339W PF:0.9540 Freq:49.99Hz Lamp Flux:1339.9x1 lm		
NAME: 2319.201F-AD3-350	TYPE:	WEIGHT:
SPEC.: 3000K	DIM.:	SERIAL No.: 2306190791
MFR.: RISE	SUR.: 0.00101736m2	Shielding Angle:

cc	80%			70%			50%			30%			10%			0
w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
fc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio															



C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:zoe
Test Date:2023-6-19

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.461
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks: LAMP:BXRE-30H1000-A-83 Ra:97
LENS: 20R
DRIVER:RMS-15-350AS 350mA
30minutes warm-up

WEC AND CCEC

Test:U:220.08V I:0.0681A P:14.339W PF:0.9540 Freq:49.99Hz Lamp Flux:1339.9x1 lm		
NAME: 2319.201F-AD3-350	TYPE:	WEIGHT:
SPEC.: 3000K	DIM.:	SERIAL No.: 2306190791
MFR.: RISE	SUR.: 0.00101736m2	Shielding Angle:

cc	80%			70%			50%			30%			10%			0	
w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
fc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients(WEC)										
0.0																	
1.0	.021	.012	.004	.020	.011	.004	.018	.010	.003	.015	.009	.003	.013	.008	.003		
2.0	.019	.010	.003	.018	.010	.003	.016	.009	.003	.014	.008	.003	.013	.007	.002		
3.0	.017	.009	.003	.017	.009	.003	.015	.008	.002	.014	.007	.002	.012	.007	.002		
4.0	.016	.008	.002	.015	.008	.002	.014	.007	.002	.013	.007	.002	.012	.006	.002		
5.0	.015	.008	.002	.014	.007	.002	.013	.007	.002	.012	.006	.002	.011	.006	.002		
6.0	.014	.007	.002	.013	.007	.002	.012	.006	.002	.012	.006	.002	.011	.006	.002		
7.0	.013	.006	.002	.012	.006	.002	.012	.006	.002	.011	.006	.002	.010	.005	.002		
8.0	.012	.006	.002	.012	.006	.002	.011	.006	.002	.010	.005	.002	.010	.005	.001		
9.0	.011	.006	.002	.011	.005	.002	.011	.005	.001	.010	.005	.001	.009	.005	.001		
10.0	.011	.005	.001	.011	.005	.001	.010	.005	.001	.010	.005	.001	.009	.005	.001		

cc	80%			70%			50%			30%			10%			0	
w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
fc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients(CCEC)										
0.0	.036	.036	.036	.031	.031	.031	.021	.021	.021	.012	.012	.012	.004	.004	.004		
1.0	.032	.030	.029	.027	.026	.025	.019	.018	.017	.011	.010	.010	.003	.003	.003		
2.0	.028	.025	.023	.024	.022	.020	.016	.015	.014	.009	.009	.008	.003	.003	.003		
3.0	.025	.022	.019	.021	.019	.017	.015	.013	.012	.008	.008	.007	.003	.002	.002		
4.0	.022	.019	.016	.019	.016	.014	.013	.011	.010	.008	.007	.006	.002	.002	.002		
5.0	.020	.016	.013	.017	.014	.012	.012	.010	.008	.007	.006	.005	.002	.002	.002		
6.0	.018	.014	.011	.016	.012	.010	.011	.009	.007	.006	.005	.004	.002	.002	.001		
7.0	.016	.013	.010	.014	.011	.009	.010	.008	.006	.006	.004	.004	.002	.001	.001		
8.0	.015	.011	.008	.013	.010	.007	.009	.007	.005	.005	.004	.003	.002	.001	.001		
9.0	.014	.010	.007	.012	.009	.006	.008	.006	.005	.005	.004	.003	.002	.001	.001		
10.0	.013	.009	.007	.011	.008	.006	.008	.006	.004	.004	.003	.002	.001	.001	.001		

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:zoe
Test Date:2023-6-19

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.461
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks: LAMP:BXRE-30H1000-A-83 Ra:97
LENS: 20R
DRIVER:RMS-15-350AS 350mA
30minutes warm-up

UGR(Unified Glare Rating) Table

Test:U:220.08V I:0.0681A P:14.339W PF:0.9540 Freq:49.99Hz Lamp Flux:1339.9x1 lm											
NAME: 2319.201F-AD3-350					TYPE:			WEIGHT:			
SPEC.: 3000K					DIM.:			SERIAL No.: 2306190791			
MFR.: RISE					SUR.: 0.00101736m2			Shielding Angle:			
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions	Viewed crosswise					Viewed endwise					
x = 2H y = 2H	5.1	5.5	5.3	5.7	5.8	3.6	4.0	3.8	4.2	4.3	
	3H	4.9	5.4	5.2	5.6	5.7	3.4	3.9	3.7	4.1	4.2
	4H	4.9	5.3	5.1	5.5	5.7	3.4	3.8	3.6	4.0	4.2
	6H	4.8	5.2	5.0	5.4	5.6	3.3	3.7	3.6	3.9	4.2
	8H	4.7	5.1	5.0	5.4	5.6	3.2	3.6	3.5	3.9	4.1
	12H	4.7	5.1	5.0	5.3	5.6	3.2	3.6	3.5	3.8	4.1
4H	2H	4.9	5.3	5.1	5.5	5.7	3.4	3.8	3.6	4.0	4.2
	3H	4.7	5.1	5.0	5.3	5.6	3.2	3.6	3.5	3.8	4.1
	4H	4.6	5.0	4.9	5.2	5.5	3.1	3.5	3.4	3.8	4.0
	6H	4.5	4.8	4.9	5.1	5.5	3.0	3.3	3.4	3.7	4.0
	8H	4.4	4.7	4.8	5.1	5.4	3.0	3.3	3.3	3.6	4.0
	12H	4.4	4.7	4.8	5.0	5.4	2.9	3.2	3.3	3.5	3.9
8H	4H	4.4	4.7	4.8	5.1	5.4	3.0	3.3	3.3	3.6	4.0
	6H	4.3	4.6	4.7	5.0	5.4	2.8	3.1	3.2	3.5	3.9
	8H	4.2	4.5	4.7	4.9	5.3	2.8	3.0	3.2	3.4	3.8
	12H	4.2	4.4	4.6	4.8	5.3	2.7	2.9	3.2	3.3	3.8
12H	4H	4.4	4.7	4.8	5.0	5.4	2.9	3.2	3.3	3.5	3.9
	6H	4.2	4.5	4.7	4.9	5.3	2.8	3.0	3.2	3.4	3.8
	8H	4.2	4.4	4.6	4.8	5.3	2.7	2.9	3.2	3.3	3.8
Variations with the observer position at spacings(CIE Pub.117):											
S = 1.0H	+ 2.7 / -15.5					+ 2.6 / -14.2					
1.5H	+ 4.7 / -12.3					+ 4.3 / -11.5					
2.0H	+ 8.1 / -14.7					+ 7.5 / -16.1					

CIE Pub.117, 1340 lm Total Lamp Luminous Flux Correct (8log(F/F0) = 1.0)
Area: 0.00101736 m2

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:zoe
Test Date:2023-6-19

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.461
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks: LAMP:BXRE-30H1000-A-83 Ra:97
LENS: 20R
DRIVER:RMS-15-350AS 350mA
30minutes warm-up

UTILIZATION FACTORS TABLE

Test:U:220.08V I:0.0681A P:14.339W PF:0.9540 Freq:49.99Hz Lamp Flux:1339.9x1 lm		
NAME: 2319.201F-AD3-350	TYPE:	WEIGHT:
SPEC.: 3000K	DIM.:	SERIAL No.: 2306190791
MFR.: RISE	SUR.: 0.00101736m2	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS(PERCENT) $k(RI) \times RCR = 5$									
k = 0.60	17	16	16	17	16	16	17	16	16	15
0.80	19	18	17	19	18	17	18	18	17	16
1.00	19	19	18	19	18	18	19	18	18	17
1.25	20	19	19	20	19	19	20	19	18	18
1.50	21	20	19	20	20	19	20	19	19	18
2.00	21	20	20	21	20	20	20	20	19	18
2.50	21	21	20	21	20	20	20	20	20	19
3.00	22	21	20	21	21	20	21	20	20	19
4.00	22	21	21	22	21	21	21	21	20	19
5.00	22	22	21	22	21	21	21	21	21	19
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:zoe
Test Date:2023-6-19

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.461
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks: LAMP:BXRE-30H1000-A-83 Ra:97
LENS: 20R
DRIVER:RMS-15-350AS 350mA
30minutes warm-up

ISOCANDELA DIAGRAM

Test:U:220.08V I:0.0681A P:14.339W PF:0.9540 Freq:49.99Hz Lamp Flux:1339.9x1 lm		
NAME: 2319.201F-AD3-350	TYPE:	WEIGHT:
SPEC.: 3000K	DIM.:	SERIAL No.: 2306190791
MFR.: RISE	SUR.: 0.00101736m2	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:zoe
Test Date:2023-6-19

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.461
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks: LAMP:BXRE-30H1000-A-83 Ra:97
LENS: 20R
DRIVER:RMS-15-350AS 350mA
30minutes warm-up

AAI Figure

Test:U:220.08V I:0.0681A P:14.339W PF:0.9540 Freq:49.99Hz Lamp Flux:1339.9x1 lm		
NAME: 2319.201F-AD3-350	TYPE:	WEIGHT:
SPEC.: 3000K	DIM.:	SERIAL No.: 2306190791
MFR.: RISE	SUR.: 0.00101736m2	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:zoe
Test Date:2023-6-19

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.461
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks: LAMP:BXRE-30H1000-A-83 Ra:97
LENS: 20R
DRIVER:RMS-15-350AS 350mA
30minutes warm-up

ISOLUX DIAGRAM

Test:U:220.08V I:0.0681A P:14.339W PF:0.9540 Freq:49.99Hz Lamp Flux:1339.9x1 lm		
NAME: 2319.201F-AD3-350	TYPE:	WEIGHT:
SPEC.: 3000K	DIM.:	SERIAL No.: 2306190791
MFR.: RISE	SUR.: 0.00101736m2	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:zoe
Test Date:2023-6-19

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.461
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks: LAMP:BXRE-30H1000-A-83 Ra:97
LENS: 20R
DRIVER:RMS-15-350AS 350mA
30minutes warm-up

LED Avg.L Report

Test:U:220.08V I:0.0681A P:14.339W PF:0.9540 Freq:49.99Hz Lamp Flux:1339.9x1 lm		
NAME: 2319.201F-AD3-350	TYPE:	WEIGHT:
SPEC.: 3000K	DIM.:	SERIAL No.: 2306190791
MFR.: RISE	SUR.: 0.00101736m2	Shielding Angle:


AvgL	cd/m2
L_0~180(65)av	62
L_0~180(75)av	5
L_0~180(85)av	0
L_90~270(65)av	69
L_90~270(75)av	11
L_90~270(85)av	0
L_45(65)av	65
L_45(75)av	3
L_45(85)av	0

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:zoe
Test Date:2023-6-19

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.461
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks: LAMP:BXRE-30H1000-A-83 Ra:97
LENS: 20R
DRIVER:RMS-15-350AS 350mA
30minutes warm-up

Planar Illuminance Curve



C Range: 0 - 360DEG
 C Interval: 30.0DEG
 Test Speed: HIGH
 Temperature: 25.3 °C
 Operators: zoe
 Test Date: 2023-6-19

Range: 0 - 180DEG
 Interval: 1.0DEG
 Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.461
 Humidity: 65.0%
 Test Distance: 3.160m [K=1.0000]
 Remarks: LAMP: BXRE-30H1000-A-83 Ra: 97
 LENS: 20R
 DRIVER: RMS-15-350AS 350mA
 30minutes warm-up

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:220.08V I:0.0681A P:14.339W PF:0.9540 Freq:49.99Hz Lamp Flux:1339.9x1 lm		
NAME: 2319.201F-AD3-350	TYPE:	WEIGHT:
SPEC.: 3000K	DIM.:	SERIAL No.: 2306190791
MFR.: RISE	SUR.: 0.00101736m2	Shielding Angle:

Table--1

UNIT: cd

C(DEG) (DEG)	0	30	60	90	120	150	180	210	240	270	300	330						
0	2062	2062	2062	2062	2062	2062	2062	2062	2062	2062	2062	2062						
5	1971	1971	1958	1950	1942	1940	1936	1934	1942	1950	1956	1961						
10	1818	1810	1783	1791	1772	1745	1740	1742	1759	1771	1796	1817						
15	5.29	5.17	12.9	5.11	5.80	4.87	2.63	2.66	2.75	2.89	2.99	2.98						
20	4.85	4.62	4.42	4.44	4.41	4.36	2.35	2.41	2.54	2.80	2.90	2.88						
25	10.6	9.90	6.86	5.78	5.29	4.98	3.13	3.73	5.00	8.16	9.87	9.09						
30	13.8	14.4	8.90	7.41	5.48	4.53	4.33	5.93	8.27	12.9	16.9	15.0						
35	10.7	12.1	8.56	8.27	6.02	4.75	4.45	6.29	7.98	10.8	13.7	13.5						
40	6.51	6.89	5.66	5.89	4.48	3.42	3.35	4.62	5.52	6.04	8.21	7.97						
45	3.34	3.00	2.88	3.21	2.62	1.82	2.06	2.68	2.90	2.50	3.95	3.81						
50	1.02	0.63	1.01	1.06	0.90	0.65	0.79	0.80	0.86	0.70	1.03	1.02						
55	0.32	0.32	0.31	0.32	0.33	0.32	0.29	0.29	0.29	0.30	0.30	0.30						
60	0.13	0.13	0.13	0.14	0.15	0.14	0.12	0.11	0.11	0.12	0.12	0.12						
65	0.03	0.03	0.03	0.03	0.04	0.03	0.02	0.02	0.02	0.02	0.02	0.02						
70	0.00	0.00	0.00	0.00	0.01	0.01	0.00	0.00	0.00	0.00	0.00	0.00						
75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
80	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
100	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
105	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
110	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
115	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
120	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
125	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
130	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
135	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
140	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
145	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
150	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
155	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
160	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
165	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
170	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
175	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						
180	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00						

C Range: 0 - 360DEG
C Interval: 30.0DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:zoe
Test Date:2023-6-19

Range: 0 - 180DEG
Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.461
Humidity:65.0%
Test Distance:3.160m [K=1.0000]
Remarks: LAMP:BXRE-30H1000-A-83 Ra:97
LENS: 20R
DRIVER:RMS-15-350AS 350mA
30minutes warm-up